



Certificat d'examen UE de type - Réglement (UE) 2016/426 « Appareils à gaz » EU Type-Examination Certificate - « Gas appliances » (EU) 2016/426 Regulation AB Tip Testi sertifikası - «Gaz Yakan Cihazlar» (EU) 2016/426 Yönetmeliği Certificat numéro / Numara 1312CT6276

CERTIGAZ, après examen et vérifications, certifie que l'appareil :

CERTIGAZ, after examination and verifications, certifies that the appliance: CERTIGAZ, Tip testi ve değerlendirmelerden sonra cihazları belgelendirmiştir

- Fabriqué par :

ALARKO CARRIER SANAYI VE TICARET AS

Manufactured by:

Gebze/TURKEY

Üretici :

Marque commerciale et ALARKO - CARRIER

modèle(s):

Trade mark and model(s): 48UA/UH045-120

Ticari Marka ve Model(ler)

Genre de l'appareil :

Kind of the appliance: Packaged Rooftop Gas Heating Units designed and built for

commercial and industrial use.

Cihaz Tipi: - Désignation du type :

48UA045150, 48UA045160, 48UA055150, 48UA055160, 48UA065160, 48UA065170,

Type designation: Tip tanımı:

48UA075160, 48UA075170, 48UA085255, 48UA085266, 48UA100255, 48UA100266, 48UA120266, 48UA120277, 48UH045150, 48UH045160, 48UH055150, 48UH055160, 48UH065160, 48UH065170, 48UH075160, 48UH075170, 48UH085255, 48UH085266,

48UH100255, 48UH100266, 48UH120266, 48UH120277

Pays de destination Destination countries / Varış Ülkeleri	Pression Pressure (mbar) / Basınç(mbar)	Catégories Categories / Kategoriler
DE, LU & PL	20	I2E
BE	20/25	I2E(R)B
AT, DK, EE, FI, GR, IT, LV, LT, NO & SE	20	12H
BE, GR, & LU	37	13P
PL	20 & 36	II2E3P
DE	20 & 50	II2E3P
CH, CZ, ES, GB, IE, SK & SI	20 & 37or 50	II2H3P
PT, RO & TR	20 & 37	II2H3P
FR	20/25 & 37 or 50	II2Er3P
HU	25 & 50	II2Hs3P

*not applicable/mandatory today, but may be accepted as conformity approval as soon as Gas Appliances (EU) 2016/426 Regulation would be transposed in national legislation

est conforme aux exigences essentielles du Réglement (UE) 2016/426 « Appareils à gaz »).

is in conformity with essential requirements of (« Gas appliances » (EU) 2016/426 Regulation.

« Gaz yakan cihazlar » (EU) 2016/426 Yönetmeliğinde belirtilen temel şartları sağlamaktadır Toute reproduction de ce certificat doit l'être dans son intégralité. Reproduction of this certificate must be in full.Bu sertifikanın yeniden basılması bütünüyle yapılmalıdır 1/XCe certificat est valide 10 ans à partir de la date de signature. Il annule tout certificat antérieur. Validity date 10 years since signature day. It cancels any previous

certificate. Geçerlilik tarihi imzalandığı günden itibaren 10 yıldır. Diğer sertifikaların yerine geçer

ET SERVICES Accréditation N°5-0042 Portée disponible sur www.cofrac.fr

Neuilly, le 22 mars 2018

Le Directeur Général

Vincent DELARUE